



CERTIFICATE OF APPROVAL No CF 5906

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

DOOR-STOP INTERNATIONAL (DSI) Subsidiary of Premdor Crosby Limited

Export drive, Huthwaite, Notts. NG17 6AF
Tel No: 01623 446336

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT	TECHNICAL SCHEDULE
FD30 Certificated Apartment Entrance Timber Doorsets with GRP Facings	TS10 Fire Resisting Pedestrian Type Hinged or Pivoted Doorsets with Non-Metallic Leaves

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 14th August 2020
Audit Test Frequency: Every 5 years
Valid to: 13th August 2025





CERTIFICATE No CF5906

DOOR-STOP INTERNATIONAL

DOOR-STOP INTERNATIONAL (DSI) – FD30 CERTIFICATED APARTMENT ENTRANCE TIMBER DOORSETS WITH GRP FACINGS

This approval relates to the use of the above doorsets in providing fire resistance of 30 minutes insulation (if incorporating not more than 20% of uninsulating glass) and 30 minutes integrity as defined in BS 476: Part 22. Subject to the undermentioned conditions, the doorsets would be expected to meet the relevant requirements of BS 9999 for FD30 doorsets when used in accordance with the provisions therein.

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. The doorsets are approved on the basis of:
 - i) Initial type testing
 - ii) A design appraisal against TS10
 - iii) Inspection and surveillance of factory production control
 - iv) Certification under a CERTIFIRE approved Quality Management System
 - v) Audit testing in accordance with TS10
3. The doors comprise cellulosic cored leaves with GRP faces for use with Veka Halo System 10 PVC-U frames, with intumescent edge seals (ITC).
4. This approval is applicable to complete doorsets only. It is a condition of this approval that an agreed Data Sheet accompanies the product and is complied with in its entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the doorset.
5. This approval is applicable to latched and bolted, single-acting, single-leaf, doorsets, with maximum leaf dimensions as stated in Table 1 below:

Doorset configuration	Maximum Leaf Height (mm)	Maximum Leaf Width (mm)	Maximum Leaf Area (m ²)
Single-Acting, Single-Leaf Latched & bolted (top / middle / bottom) Opening In / Opening Out	2013 (at 910 wide)	910 (at 2013 high)	1.83

Table 1

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

Signed Page
E/254

2 of 3

Issued: 14th August 2020
Valid to: 13th August 2025



CERTIFICATE No CF5906 DOOR-STOP INTERNATIONAL

DOOR-STOP INTERNATIONAL (DSI) – FD30 CERTIFICATED APARTMENT ENTRANCE TIMBER DOORSETS WITH GRP FACINGS

These doorsets are approved for use with and without glazed toplights with maximum overall frame dimensions as stated in Table 2 below:

Doorset configuration	Maximum Height (mm)	Maximum Width (mm)
Frame	2081 (at 1018 wide)	1018 (at 2081 high)
Toplight (excluding hardwood coupler)	415 (at 1018 wide)	1018 (at 415 high)
Frame & Toplight (including hardwood coupler)	2500 (at 1018 wide)	1018 (at 2500 high)

Table 2

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

The maximum frame dimensions stated in Table 2 do not include frame Knock Ons, which are permitted to be added where required.

- Glazing shall only be undertaken by the doorset manufacturer and shall be in accordance with the Data Information sheet and Construction Specification. No site cutting or glazing of apertures is permitted.
- Hardware items, including closing devices and intumescent fire seals, shall be as specified in the Data Sheet.
- The doorset shall be mechanically fixed to wall constructions having a fire resistance of at least 30 minutes as specified in the Data Sheet.
- Labels to the CERTIFIRE design, or approved by CERTIFIRE, referencing CERTIFIRE and CERTIFIRE Ref. No. CF5906 and FD30 classifications resistance shall be affixed to each door in the prescribed position.
- This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application when appropriate.

Signed Page
E/254

3 of 3

Issued: 14th August 2020
Valid to: 13th August 2025